



NOTES:

1. 1' CLEARANCE TO BE PROVIDED BETWEEN UTILITIES AND STORM DRAIN OR SANITARY SEWER AT CROSSINGS.
2. WATER LINE "WINDOW" TO REMAIN AT A DEPTH OF 42" MINIMUM TO TOP OF PIPE FROM FINISH GRADE. ALL OTHER UTILITIES PER UTILITY COMPANY SPECIFICATIONS.



NORTHSTAR C.S.D.

JOINT TRENCH DETAIL

908 NORTHSTAR DR. TRUCKEE, CA

DATE: APR. 2003

DRAWN: JW

APPROVED: MS

SCALE: NONE

DIR.: WATER

DWG. FILE: WO-8

FIGURE:

8